



IF REMOTE ALARM LIGHTS ARE INSTALLED, THE INTERCONNECTING LEAD LENGTHS SHOULD NOT EXCEED 12". SEE SPECIFICATIONS FOR MAXIMUM CURRENT DRAW.

FREQUENCY SENSING FROM MAIN AC GENERATOR

A	05/25/04	ADDED WIRE LENGTH SPEC	DSB
REV	DATE	DESCRIPTION	DWN BY

Bouchette Electronics, Inc.
 N11325 County Highway Y Clintonville, WI 54929

TITLE CONNECTION DIAGRAM
 B120AK

DATE	DWN BY	CHK	SCALE
03/30/99	DSB	TJB	NONE
P/N	CAD REF	DWG NO	
	PCB13B	E194-11	